



Windowhalt Motorised

Integrity only single coil small span fire curtain specification

PERFORMANCE REQUIREMENT:

The vertical fire curtains shall be supplied and installed in accordance with AS1905.2:2005 and the primary means of activation shall be an AS1905.2:2015 fusible link. When fire tested in accordance with Clause 3 Determination of Fire Resistance, they shall provide a minimum Fire Resistance Level (FRL) of -/120/- and radiation transmission of no more than 15kW/m² measured at 365mm at 30 minutes. The fabric barrier shall have fire hazard properties of a Group 1 rating when tested in accordance with NCC Specification C1.10 Clause 4 Wall and Ceiling linings.

The fire curtains shall resist a pressure differential of no more than 20 Pa when fully deployed.

PRODUCT SPECIFIED

Fyrehalt V fire curtain by Smoke Control T: 1300 665 471; info@smokecontrol.com.au or approved equivalent.

System parameters;

- a) -/120/- FRL AS1530.4:2014
- b) Smoke leakage: ≤ 75m³/hour AS1530.7:1997 (3.3 x 3.3m tested system).
- c) Maximum size;
 - i) 8m W x 3m H; or
 - ii) 6m W x 4m H
- d) Deployment speed nominally 150mm/s (AS1905.2:2015)
- e) Dimensions
 - i) Headbox – 165mm H x 165mm D
 - ii) Side Guide – 100mm W x 50mm D
- f) Power requirements – 240v 10amp GPO, peak current draw 2.1amps
- g) Alarm input – 0V nominally closed contacts
- h) Pressure resistance maximum;
 - i) 0Pa when deploying
 - ii) 20Pa when deployed
- i) System weight;
 - i) 20kg/m of system width up to 3m H
 - ii) 25kg/m of system width up to 4m H
- j) Supporting construction type;
 - i) Masonry
 - ii) Concrete
 - iii) Fire rated plasterboard with steel or timber stud.
- k) Approved installation configuration;
 - i) Headbox;
 - i. Face fixed to the wall
 - ii. Fixed under the slab/into the wall
 - ii) Side guides;
 - i. Face fixed to the wall
 - ii. Fixed in the opening

Auxiliary items available;

- i) Control system: Shall allow fail safe operation on activation via fusible link. Activation via other device possible within scope of AS1905.2:2015. Fusible link will require service to facilitate rewind post-activation.
- ii) Battery backup; Available on request to reduce the likelihood of nuisance deployments and allow 5 complete open-close cycles.
- iii) Rewind switches (operating ΔPa = 0): Available on request and shall be installed on both sides/one side of the nominated fire curtains. They shall allow the system to rewind no more than 2.1m and redeploy within 20 seconds from top position.

- iv) Exclusion Zone Sensors; Available on request. IRS36 shall be installed in accordance with Smoke Control's recommendations to protect each fire curtain asset during normal building use and significantly increase the likelihood of full deployment when in fire mode.
- v) Sounders and strobes; Available on request. Shall be installed on both sides/on the same side as the egress path and operate on a signal from the FIP or other activation device.
- vi) Fire Rated Bulkhead; shall be installed (by others) to provide an FRL of -/120/120 when fire tested in accordance with AS1530.4 and shall facilitate any service penetrations to be installed and certified in accordance with AS4072.1:2005
- vii) Fire Rated Corner posts: shall be installed at fire curtain junctions in strict accordance with the manufacturer's approvals.
- viii) Third Party Product Listing: The product shall be manufactured under the Third Party Product Listing scheme known as the Warnock Hersey Mark and shall bear the Warnock Hersey Certification Mark.

Maintenance: All fire curtains shall be listed on the Essential Services Register and shall be maintained by competent technicians in accordance with AS1851 and the manufacturers recommendations

APPLICATIONS

- Protection of openings in external walls (NCC C3.4)
- Protection of openings in fire compartment walls (NCC C3.5)
- Non-required stairways, ramps and escalators (D1.12 & Spec D1.12)
- Construction of proscenium walls (Specification H1.3)
- Separation of fire compartment where it exceeds maximum size or volume (C2)
- Servery openings in smoke-proof walls health-care and residential care buildings (C2.5, Spec C2.5)

Note: Some applications listed above may require a Performance Solution to be compliant. Please check with your Certifier prior to specifying this product.

INSTALLATION

Fire Curtains

The fire curtains shall be installed, certified, commissioned and tagged in accordance with AS1905.2 -2005 by an ISO9001 Quality, ISO18001 WHS and ISO14001 Environment Accredited manufacturer.

When installed the system shall consist of a single overhead barrel for the full width of the opening. While some Registered Testing Authorities provide Formal Opinions in regards to the expected fire resistance level of fire curtains, they do not discuss nor provide a warranty in regards to their reliability. Experience shows that some manufacturer designs of fire curtains do not operate reliably once installed and attract extraordinarily high maintenance costs. For this reason, multiple barrel, overlapped fire curtains are deemed not equivalent to this specification on this project and shall not be substituted for a single barrel continuous span system.

Threshold

Unless addressed as part of an appropriate performance solution the curtain must deploy onto a fire rated or non-combustible threshold as per requirements of AS1905.2:2005 and AS1530.4:2014. Maximum gap permitted at threshold 25mm.

Fire Rated Bulkheads

The fire rated bulkhead shall be installed as a 3-sided bulkhead (the fourth side is provided by the concrete slab) to provide a minimum of -/120/120 fire resistance level when tested in accordance with AS1530.4 and provide complete encasement of the fire curtain suspension system. This configuration will allow for certification of any service penetrations which will also be required to be certified in accordance with AS4072.1:2005

COMMISSIONING

Once installed it shall be demonstrated that the system shall failsafe close on loss of power using mains power in combination with battery backup and on activation by fusible link. On reset of power and the fusible link, the system shall automatically rewind to its standby position without the assistance of an occupant or technician.

The fire curtains shall also be commissioned in conjunction with the building's smoke management system. The smoke management system shall be balanced to operate without adverse effects to the fire curtain. The fire curtains must be tested a minimum of 3 consecutive times on general building alarm without failure.

The building's smoke management system shall not impede the operation of the fire curtain. A time delay of 60 seconds shall be incorporated into the smoke management system before it operates to allow the fire curtain to deploy to its fire mode position without interference. This shall be programmed within the Fire Indicator Panel. Consideration shall be made for the staged deployment of the fire curtain.

Similarly, a time delay of 60 seconds shall be incorporated into the reset of the alarm signal to fire curtain to ensure the smoke management system has ceased operation and the effects of pressure differentials have been dispersed prior to rewind of the curtain.

Certificates of Compliance shall be issued by the sub-contractor in accordance with National Construction Code A2.2 and A2.3 Evidence of Suitability, and AS1905.2:2005 Clause 7 Certification.

All details and approvals are current as of the date displayed. This document supersedes all previous versions.